

DEPARTMENT OF GLASS TECHNOLOGY

**TEST REPORT No. 028.W.17.N
CONCERNING ASSESSING THE
PERFORMANCE****4. Assessing the performance**

The construction product - flat bronze thermally toughened soda lime silicate safety float glass with nominal thickness of 4 mm produced by UAB "BODESA" from Lithuania

- has the following performance:

pendulum body impact resistance - 1/C/1 class in accordance with standard EN 12600: 2002



.....
/ signature of the person drawing up
the report /



.....
/ signature of person assessing the
performance /

Z-ca KIEROWNIKA
Zakładu Technologii Szkła

mgr Inż. Anna Balon-Wróbel

.....
/ signature of the person authorizing
test report /

Reservations:

1. The test results refer only to the tested samples.
2. Without consent of the Department of Glass Technology on paper, the report cannot be duplicated otherwise than as a whole.
3. Deadline for the submission of complaints must not exceed 1 month from the date of the test report drawing up.
4. The statement(s) of compliance with specification (or requirements) is (are) based on expanded uncertainty with confidence level of 95% for test results on which the decision is based on compliance. The uncertainty does not include the step of sampling.