


DEPARTMENT OF GLASS TECHNOLOGY


**TEST REPORT No. 031.W.17.N  
CONCERNING ASSESSING THE  
PERFORMANCE****4. Assessing the performance**

The construction product - flat low-E thermally toughened soda lime silicate safety float  
"4 mm G fast" glass produced by UAB "BODESA" from Lithuania - has the following  
performance:

pendulum body impact resistance - 1/C/2 class in accordance with standard EN 12600: 2002

  
.....  
/ signature of the person drawing up  
the report /

  
.....  
/ signature of person assessing the  
performance /

Z-ca KIEROWNIKA  
Zakładu Technologii Szkła  
  
mgr inż. Anna Balon-Wróbel  
  
.....  
/ signature of the person authorizing  
test report /

**Reservations:**

1. The test results refer only to the tested samples.
2. Without consent of the Department of Glass Technology on paper, the report cannot be duplicated otherwise than as a whole.
3. Deadline for the submission of complaints must not exceed 1 month from the date of the test report drawing up.
4. The statement(s) of compliance with specification (or requirements) is (are) based on expanded uncertainty with confidence level of 95% for test results on which the decision is based on compliance. The uncertainty does not include the step of sampling.